



EEE Consulting, Inc.

Environmental, Engineering and Educational Solutions

April 30, 2018

Ed Buzzelli
Hanover County Public Schools
Director of Facilities
Email Delivery: ebuzzelli@hanover.k12.va.us

Re: Summary of Water Testing at Hanover County Public Schools
3e Projects 17-191 and 18-010

Dear Ed,

EEE Consulting, Inc. (3e) has completed the testing of high priority drinking water sources at sixteen (16) Hanover County Public Schools. The testing was conducted in response to Virginia Code 22.1-135.1 Potable water; lead testing, which requires each local school board to test high priority potable water sources at public school facilities with buildings constructed, in whole or in part, before 1986. Hanover County identified sixteen (16) public school facilities which meet these criteria.

The sampling was completed in accordance with the EPA Revised Technical Guidance, "3Ts for Reducing Lead in Drinking Water in Schools". Individual reports for each school were submitted under separate cover. The attached table summarizes the schools tested, the results of the testing, and recommendations based on the test results.

If you have any questions please contact us at (804) 442-3330.

Sincerely,

A handwritten signature in blue ink that reads "Carroll H. Ellis, III".

Carroll H. Ellis, III
Environmental Scientist

A handwritten signature in blue ink that reads "Sharon Ward Harless".

Sharon Ward Harless
Senior Vice President

Summary of High Priority Water Source Testing - Hanover County Public Schools

School Facility	Number of High Priority Water Sources Sampled at School	Number of Water Sources Exceeding EPA action level	Recommendations
Battlefield Park Elementary	26	2	Replace fountain/chiller BPES-DF-04 and BPES-DF-22.
Beaverdam Elementary	18	2	Replace fountain/chiller BES-DF-11 and BES-DF-14.
Cold Harbor Elementary	46	0	N/A
Elmont Elementary	30	0	N/A
Henry Clay Elementary	27	1	Replace fountain/chiller HCES-DF-09.
John Gandy Elementary	10	0	N/A
Lee Davis High	18	0	N/A
Liberty Middle	26	0	N/A
Mechanicsville Elementary	42	0	N/A
Patrick Henry High	20	1	Replace fountain/chiller PHHS-DF-05.
Pearsons Corner Elementary	12	0	N/A
Rural Point Elementary	17	3	Replace fountain/chiller RPES-DF-01, RPES-DF-10, RPES-DF-11
School Board Office	6	0	N/A
South Anna Elementary	41	4	Replace fountain/chiller SAES-DF-01, SAES-DF-05, SAES-DF-32, and SAES DF-40.
Stonewall Jackson Middle	26	0	N/A
Washington Henry Elementary	22	0	N/A
Totals	387	13	